



NOTE:

1. THE CONCRETE USED SHALL BE PORTLAND CEMENT, AIR-ENTRAINED, CLASS "A" CONCRETE WITH AN AIR CONTENT OF 5%, MIN., TO 7%, MAX., AND A SLUMP OF THREE INCHES, MIN., TO FIVE INCHES, MAX.
2. ALL CONCRETE SIDEWALK REPLACEMENT SHALL BE TO FULL PANEL LIMITS, PARTIAL PANEL REPLACEMENT SHALL NOT BE ALLOWED.
3. ALL SIDEWALKS SHALL BE FINISHED WITH A MAGNESIUM FLOAT FINISH UNLESS DIRECTED OTHERWISE BY THE CITY.
4. ALL CURBING SHALL BE RESET OR REPLACED AS REQUIRED, IN ACCORDANCE WITH CITY DETAILS.
5. EXPANSION JOINTS TO BE PLACED BETWEEN ADJACENT SLABS, AT BUILDING LINE, AT CURBS, OR AT PENETRATING STRUCTURES.

NO SCALE



Gerald D. Jennings, Mayor
Deirdre J. Rudolph P.E., City Engineer

**CITY OF ALBANY DIVISION OF ENGINEERING
STANDARD DETAILS**

DETAIL NAME:

**SIDEWALK REPLACEMENT
DETAIL**

DETAIL No.

SW-1

FILE NAME:

SW-1.DWG

DATE ISSUED

05/01/02

REVISION DATE

05/01/02